

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:00 pm

PWS ID: UTAH10022 **Name:** ARCHES NP-DEVILS GARDEN

Legal Contact: NPS - ARCHES NATIONAL PARK **Rating:** Approved
KATE CANNON **Rating Date:** 04/09/1996

Address: 2282 SW RESOURCE BLVD **Activity Status:** Active
MOAB, UT 84532

Phone Number: 435-719-2251

City Served (Area):

County: GRAND COUNTY

System Type: Non-community **Last Inv Update:** 12/09/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 10/06/2010 **Total Dsgn Cap:**
Population: 25 **Surveyor:** DAVID ARIOTTI **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Phone Numbers Office Emergency	Email Address
AC	CANNON, KATE	SUPERINTEND	435-719-2101	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	7
			7 Total Svc Connections

Storage

Total Storage: 30,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	30,000 GAL	Steel		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP001	WELL 2 HYPOCHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	WELL #2	Active	WL	6	5 GPM	7 GPM	Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.